

Cooling thermal load calculation

Project: Test project
Made by: Doe John
Cooling test Ltd.

Date: 2017.09.3
Phone: +2545852147
E-mail: johndoe@example.com

General informations:

| | | |
|-----------------------------|-----------------------------|-------------------------|
| Mode: normal | Defrosting system: Electric | Air change: normal |
| Cooling temp: 0 °C | Number of defrost: 4 | Hours run per day: 18 h |
| Contingency allowance: 10 % | | |

Chamber data:

| Side | Size | Outer temperature | K value | Insulation thickness |
|---------------|------|------------------------------|-------------|----------------------|
| A | 2 m | 36 °C | 0.037 W/m K | 70 mm |
| B | 3 m | 36 °C | 0.037 W/m K | 70 mm |
| C | 2 m | 36 °C | 0.037 W/m K | 70 mm |
| D | 3 m | 36 °C | 0.037 W/m K | 70 mm |
| E | | | | |
| F | | | | |
| Floor | | 10 °C | 0.037 W/m K | 70 mm |
| Ceiling | | 36 °C | 0.037 W/m K | 70 mm |
| Height: 2.7 m | | Volume: 16.20 m ³ | | |

Goods data:

| | | |
|--------------------------------|--------------------------------|--------------------------|
| Type: Beef | Input temp: 35 °C | Final temp: 0 °C |
| Cooling time: 24 h | Input quantity: 300 kg | Total quantity: 600 kg |
| Freezing temp: -1.7 °C | Specific heat +: 2.85 kJ/kg °C | Latent heat: 234 kJ/kg |
| Density: 445 kg/m ³ | Specific heat -: 1.76 kJ/kg °C | Respiration: 0 kJ/kg 24h |

Heat sources:

| | | |
|-------------------|----------------------|-------------------------------|
| Machines: | Output / machines.: | Machines h/day: |
| Lighting hours: 1 | Lighting load: 100 W | Lighting W / m ² : |
| Persons: 1 | Person h/day: 1 | |

Result, loads:

| | | |
|--------------------------|------------------------------------|------------------------|
| Machines: 0 W | Lighting: 4.17 W | Persons: 14.38 W |
| Air change: 300.89 W | Defrosting: 62.88 W | Cooling fans: 140.74 W |
| Goods: 346.35 W | Insulations: 702.49 W | Net: 1368.28 W |
| Hours per day: 1824.37 W | Total thermal load: 2.23 KW | |
